





H2 Refuelling Station

2022.10.26

About Port Oostende

- In just over ten years, Port Oostende has become a major hub for the offshore wind business, with 2.2 GW installed of operational capacity in the Belgian North Sea.
- Active maintenance of those parks out of Port Oostende with crew transfer vessels and service operating vessels
- With more than 800 people directly employed in the O&M business for the offshore wind in Oostende.








EXTENSION BELGIAN MARINE SPATIAL PLAN

+3,6 GW Installed 2030





2,2 GWInstalled 2020





Crew Transfer Vessels





H2SHIPS



SOV (Service Operating Vessels) - hotelvessels



Reducing the carbon footprint of an offshore windfarm




- The O&M activities in the offshore wind industry have today a considerable carbon footprint
 - The vast majority of specialized vessels for offshore wind installation, operation and maintenance are driven by internal combustion engines, mainly using fossil fuel, for propulsion.
 - This is still the case for most of the recently build Crew Transfer Vessels (during the last 5 years), which will be in use for at least another 10 to 15 years
 - For CTVs the priorities are speed, reliability and safety of transfer, while incentives on CO2 emission reduction are low, and so far little or no requirements were imposed as permit requirement or as award criteria
- Our existing BE wind farms
 - We estimate that the O&M operations and maintenance logistics for the existing BE windfarms consume
 7.5 9 million litre of diesel fuel per year, generating 20000 24000 tons of CO2 (approx. the equivalent of 3000 cars)
 - => average of 3500 to 4000 litre / year / MW of installed capacity



Incentives and Corporate Sustainability

Port Oostende

- A recent study led to the following conclusions :
 - IMO (International Marine Organisation) has committed to reduce GHG emissions by at least 50% by 2050 from the 2008 baseline
 - Carbon Price is expected to reach > 100€/ton by 2030 (source: Bloomberg NEF)
 - Aside from tangible targets, Corporate Sustainability Reporting (CSR) is becoming an important consideration for many companies to report on their own impact on people and the environment.
 - <u>RE100</u> brings together hundreds of large and ambitious businesses committed to 100% renewable energy
 - SME Climate Hub members aim to reduce their emissions by 50% in 2030, and reach zero emission by 2050
 - It is expected that permit requirements for potential lifetime extensions will increasingly focus on LCSA (Life Cycle Sustainability Assessment) considerations, and will impose qualitative and quantitative criteria.
 - The offshore wind industry leaders (Siemens Gamesa, Vestas, Orsted, Vattenfall,...) have started to also impose sustainability targets to their vessel providers a.o.
 - The first "green" CTV concepts are under development: hybrid-electric, hybrid with H2 fuel cells,..., some of which are being implemented by front-runners (e.g. Orsted in Borssele 1&2)
 - Overall, there will soon be a demand for alternatives to grey fuels for offshore wind O&M operations
















Location






H2 Refuelling Station



Status of the project


- Feasibility study:
 - Explore the potential future demand and related business model for hydrogen in the harbor of Oostende
 - ✓ Technical concept, safety screening for suitable locations, preferred location identified
- Realization of the facility:
 - ✓ Detailed engineering
 - ✓ Permit application, safety and implementation study
 - ✓ Procurement
 - Construction, commissioning, testing ongoing
- Planned capacity and phasing:
 - Phase 1: 600 kgH2/day, 4 vessels @150kg H2/day
 - Phase 2: 1600 kgH2/day, expected within x years
 - Phase 3: 3000 KgH2/day, expected within y years





– Estimated timeline:





Test & Demo as from **March 2023**

H2 refuelling station – Power installed



H2 Mass Flow 1544.648649 kg/day]										
H-Drive Parameters	Inlet Pressure (Bar)	Interstage (Bar)	Outlet Pressure	Flowrate	Flowrate (kg/hr)	Running Time	Hyd Pressure	Hyd Power	No. of	Hyd Power	Hyd Flow	Process Cooling	Total Process
												Required Per	Cooling Required Per
			(Bar)	(Nm3/hr)		(Hours)	(Bar)	(kW)	Boosters	(kW)	(I/min)	Booster (kW)	System (kW)
	99	308	500	357.2	32.18018018	24	248	73	2	146	140	37.8	60.48
	99	308	500	357.2	32.18018018	24	248	73	2	146	140	37.8	60.48
Average				357.2	32.18018018	24	248	73	2	146	140	37.8	60.48
	Maximum	Average Running		HPU Installed Pov	ver								
Total Hydraulic Power (kW) / Running (kW)	146			150	kW								
Total Process HPU Cooling Required (Per HPU / Total)	20	40				HPU TO Cooling	g:- 8 kW for 30 kW	for 55 kW mo	tor. 12/55 For 7	75 kW 16/75			
Total Process Cooling (kW)	100.48	3	1	Chiller Installed									
Total Process Electrical Power Installed (kW) / Running (kW)	49.53004953	25.4	ICE 116	42	kW	CO2 Chiller Ru	nning						
Total Dispense Cooling Electrical Power (kW) / Running (kW)	0	0)	0	kW	65							
	Maximum Installed	Average Running	Maximum Running		_								
Total Electrical Power Required (Installed / Running)	193.285	122.7236	195.5300495	kW]	150 kW Install	ed						
Safety Factor (10%)	212.6135	134.99596	215.0830545	kW]								
Total + Safety Factor (Installed / Running)	212.6135	134.99596	215.0830545	kW		Process Chiller	s						
			-										
Hydraulic Power	1.512166797]			Model ICE						150 183 230 3	
Process Power	0.394652856	5]			Cooling capacity Compt abs. power						149,2 182,3 227,9 3 30,8 40,1 51,4 4	
Dispense Power	0]			Config capacity	kW 1,8 3,8					110,9 135,4 165,3 2	
Ancillaries	0.019965705					Compr. abs. power ^c			4,46 5,93 8,26	10,6 13,1 16	4 21,2 25,8	33,5 42,1 54,3 6	
Total kWh/kg	1.926785358	kWh/kg Total (Running)				Cooling capacity Compr. abs. power	kW kW			47,6 59,0 79 9,04 11,0 13			
		-	_			Cooling capacity	kW N.A	. on r				27,6 34,8 on 116,1 144,6 request	N.A.
Ancillaries	kW					Compr. abs. power	kW			8,93 11,1 13			
Extractor Fan (x2)	0.75	i				Compressors Compr/circuits			1/1		2/2	4/2	
Fire System	0.25	i				Max abs. power - 1 compr.	kW 0,7 1,5			13,7 16,8 11		11,1 13,7 16,8 2	23,3 28,7
Lights (x2)	0.03					Axial fans							
PLC	0.025	i				Quantity	n*	014 014 055	1061 1078 061	2	3	2 3 2,0 2,0 2,0	20 20
HMI (x2)	0.05					Max abs. power - 1 fan Air flow						47000 46000 66000 88	
Solenoids (x10)	0.06					Centrifugal fans							
TT (x10)	0.06					Quantity	n°		2 2	2 3 3 1,1 1,1 1,	3 3	3 3	
PT (x10)	0.06					Max abs. power - 1 fan	W N.A	A. on r				3 3 on	N.A.

kPa

75 Kw Per booster – Total 150 Kw

50 Kw for the process chiller

10 Kw for ancillaries. – Air Compressor and PLC / Lights etc.

Total Installed 210 kW



