

REPORT



DATE: December 2022

ACTION: A1 Site selection for centralized PHA compounding and processing

SUBJECT: D1.1 Report on selection of WWTPs in 3 NWE regions that are suitable for PHA production
D1.2 Report and GIS maps about most suitable locations to realize a centralized PHA compounding and processing facility

WOW! is supported by the Interreg North-West Europe program.

WWW.NWEUROPE.EU/WOW

avans
hogeschool

WiW_{mbh} 

 **TECHNISCHE UNIVERSITÄT
KAISERSLAUTERN**

 **Trinity College Dublin**
Coláiste na Tríonóide, Baile Átha Cliath
The University of Dublin


**UNIVERSITÉ DU
LUXEMBOURG**

 **waterschap
vallei en
veluwe**

 **LAB University of
Applied Sciences**

Content

1	Introduction	5
2	Activity D1.1 – site selection	6
3	Basis for cost analysis	7
3.1	CAPEX	7
3.2	OPEX	8
3.3	Mass balance	10
4	Cost analysis and initial concepts	11
4.1	Cost in dependence of size and number of involved plant.....	11
4.2	Concepts.....	13
5	Region-specific study	15
5.1	Scotland.....	16
5.1.1	Aberdeen	16
5.1.2	Glasgow	17
5.1.3	Edinburgh	19
5.2	Saarland (region Germany)	21
5.3	Germany.....	24
5.4	Ireland	27
5.5	Conclusions GIS analysis.....	29
6	Region-specific study – Cost analysis	30
6.1	Basics for the calculation of the sludge amounts	30
6.2	Scotland.....	30
6.2.1	Primary sludge transport	30
6.2.2	PHA rich biomass transport	35
6.2.3	Estimated cost	42
6.2.4	Recommendation	46
6.3	Germany / Saarland	47
6.4	Ireland	47
6.4.1	Primary sludge transport	47
6.4.2	PHA rich biomass transport	49
6.4.3	Estimated cost	50
6.4.4	Recommendation	51
7	Conclusions	53

8	Literature	55
9	Abbreviations	56
10	Appendix	57

1 Introduction

Within the framework of WOW! Project, the market potential and technical feasibility for production of bioplastic from sewage with primary sludge (PS) as feedstock has been proved. The developed production process of bioplastic from PS is shown in Figure 1-1, which can be divided into 3 stages including PHA-enrichment, PHA-extraction and PHA-compounding.




Figure 1-1: Flow diagram of PHA production

In the report of techno-economical assessment for bioplastic production from sewage (Khan, 2021), the economic feasibility of a theoretical large-scale plant with PHA-production capacity of 5,000t/y has been assessed, which correspond to a demand of primary sludge from around 2,000,000 PE. In reality, a single WWTP with 2,000,000 PE isn't common. Therefore, for a practical capitalization of bioplastic production from sewage, possible concepts have to be studied with regard to the logistics, finances and sustainability.

This report is the deliverable 1.1 & 1.2 of Activity A1 of WOW! Capitalisation. The objective is to identify the most suitable location to realize PHA production and processing in 3 NWE regions including Scotland, Ireland and Saarland. The cost analysis serves as the basic for the location selection, which is conducted with the similar method in (Khan, 2021).

The possible concepts were firstly proposed based on preliminary cost analysis with consideration of the production process. With the help of Geographic Information System (GIS), the possible locations for the installation of system for different PHA production stages were selected to be considered as different variants. The variant - specific cost analysis was then conducted for the final determination.

2 Activity D1.1 – site selection

Before reporting on the most suitable locations to realize a centralized PHA facility – which is activity D1.2 and described further after this chapter – a site selection for this study was made.

Before the site selection, a region selection was done. It was decided to select Ireland, Scotland and Saarland in Germany as regions to analyze. The UWWTD (Urban Waste Water Treatment Directive) website was consulted to gather data for the selected regions:

- Ireland has 175 STPs spread around the country, exceeding a capacity > 2,000 PE
- Scotland has 153 STPs spread around the country, exceeding a capacity > 2,000 PE
- Germany has about 3,800 STPs spread around the country

A cut-off criteria was set initially to select only treatment facilities which have a capacity over 2,000 PE (People Equivalent). Due to the fact that Germany was too big as region for being a case study, initially it was chosen to focus on the region of Saarland with 60 STPs exceeding a capacity > 2,000 PE.

The facilities were all processed through the Decision Support Tool (developed in WPT2 of the WoW project and to be downloaded here: <https://www.coebbe.nl/projecten/wow/>).

All treatment plant without primary treatment were erased from the selection, since primary treatment is essential for PHA production. The remaining selection was processed through the DST.

The BOD/COD ratio was not known for all STPs (sewage treatment plants), for the ones which were unknown, the assumption was made it is sufficient enough to stay in the site selection. For the known ones with a ratio under the required value, these were erased from the selection.

The results were as follows (as being able to produce PHA at a single STP):

Ireland: 12 STPs were promising, 14 STPs were not yet clear and 136 STPs seemed to be not suitable

Scotland: 23 STPs were promising, 11 STPs were not yet clear and 119 STPs seemed to be not suitable

Saarland: 3 STPs were promising, 6 STPs were not yet clear and 51 STPs seemed to be not suitable

As result, the decision was taken to continue only with STPs having 10,000 PE or more. The remaining selection for all 3 regions was taken as input for activity D1.2. Further developments regarding the selection is described in the corresponding chapters in this report.

3 Basis for cost analysis

The cost analysis is conducted on the basis of the method and results presented in (Khan, 2021), which include the mass/energy balance of the PHA production, CAPEX and OPEX for a centralized plant with a PHA production and processing capacity of 5,000 t/y as well as the method used for the cost estimation.

3.1 CAPEX

Table 3-1 shows the CAPEX breakdown for the centralized plant with the capacity of 5,000 t/y

Table 3-1: CAPEX breakdown for the centralized plant with the capacity of 5000 t/y

	CAPEX breakdown ¹⁾	CAPEX (per year)	Investment cost ²⁾	Piping	Instrumentation /Electrical	Engineering cost	Civil works	Start-up	equipment cost
Plant equipment				15% E-cost ¹⁾	25% E-cost ¹⁾	10% E-cost ¹⁾	34% E-cost ¹⁾	12% E-cost ¹⁾	
Sum	100%	4,198,378	64,899,623	4,966,808	8,278,013	3,311,205	11,258,098	3,973,446	33,112,052
Fermentation reactor	14%	581,953	8,995,987	688,468	1,147,447	458,979	1,560,528	550,775	4,589,789
Centrifuge 1	14%	581,953	8,995,987	688,468	1,147,447	458,979	1,560,528	550,775	4,589,789
Selection reactor	20%	831,362	12,851,410	983,526	1,639,211	655,684	2,229,326	786,821	6,556,842
Accumulation reactor	28%	1,163,907	17,991,975	1,376,937	2,294,895	917,958	3,121,057	1,101,549	9,179,579
Centrifuge 2	15%	623,522	9,638,558	737,645	1,229,408	491,763	1,671,995	590,116	4,917,632
Dryer	2%	83,136	1,285,141	98,353	163,921	65,568	222,933	78,682	655,684
Extraction reactor	1%	41,568	642,571	49,176	81,961	32,784	111,466	39,341	327,842
Filter ³⁾									
Evaporator ³⁾									
Compounder	3%	124,704	1,927,712	147,529	245,882	98,353	334,399	118,023	983,526
Injection moulding	4%	166,272	2,570,282	196,705	327,842	131,137	445,865	157,364	1,311,368

1) Data derived from TEA

2) Investment cost was calculated based on the yearly CAPEX with the equation for cost annualisation obtained from TEA

3) There is no information about the investment cost of filter and evaporator in TEA

Together with the equation 1-1, in which A represent the equipment with a larger capacity than B, CAPEX for plant in other scale can also be estimated. The applied exponent for different equipment is also adopted from (Khan, 2021) as shown in Table 3-2. The capacity of equipment is represented by the feedstock amount of each equipment calculated with mass balance.

$$\text{Cost of equipment A} = (\text{cost of equipment B}) \times \left(\frac{\text{Capacity of A}}{\text{Capacity of B}} \right)^{\text{exponent}} \quad \text{Eq.(1-1)}$$

Table 3-2: exponent for different equipment

		Exponent
PHA-Enrichment		
1	Fermentation reactor	0.75
2	Centrifuge 1	0.6
3	Selection reactor	0.78
4	Accumulation reactor	0.78
5	Centrifuge 2	0.6
PHA-Extraction		
1	Dryer	0.6
2	Extraction reactor	0.66
3	Filter	
4	Evaporator	
PHA-Compounding		
1	Compounder	0.6
2	Injection moulding	0.6

In consideration of composition of CAPEX, 35%, 55% and 10% of total CAPEX are separately assigned to construction engineering, mechanical engineering and instrumentation/control engineering with a depreciation period of 25, 15 and 10 years respectively. With an interest rate of 2%, the yearly CAPEX can also be estimated.

3.2 OPEX

The energy, material and personal demand for each step during the PHA production and processing are also adopted from (Khan, 2021) summarized as in Table 3-3.

Table 3-3: specific energy, material and personal demand

	electricity		heat		steam		Personnel
	unit		unit		unit		(per shift)
acidogenic ferment.	kWh/m ³ _{sludge}	96.9	kWh/m ³ _{sludge}	23.4			0.02
centrifuge 1	kWh/m ³ _{sludge}	1.88					0.35
selection reactor	kWh/m ³ _{sludge}	2.51					0.5
accumul. reactor	kWh/m ³ _{sludge}	2.4					0.5
centrifuge 2	kWh/m ³ _{sludge}	1.88					0.35
dryer	kWh/kg _{evaporated water}	0.16	kWh/kg _{evaporated water}	1.45			0.5
extraction	kW/m ³	0.01			t/t _{dried, PHA-rich, biomass}	1.1	0.2
DMC stored tank							
filter							0.15
evaporator					t/t _{filtrate}	0.06	0.25
compunder	kWh/t	441.7					0.2
injection moulding	kWh/t	1503.4					0.2

For the determination of the material costs, the costs according to Table 3-4 from (Khan, 2021) and the amounts of raw materials calculated from the mass balance are taken into account.

Table 3-4: Unit price for different resource

Unit cost			
2	Electricity	93	€/MWh
3	Natural gas	34	€/MWh
4	Steam	24.6	€/t
5	Cooling water	0.5	€/m ³
6	Process water	1	€/m ³
7	Dimethyl carbonate	1	€/kg
8	Raw materials	3	€/kg
11	Labor	31.2	€/h

Furthermore, the insurance cost and maintenance cost were assumed to be 67% of labor cost and 0.5% of annualized CAPEX as in (Khan, 2021). The cost for PS and PHA-biomass transport was assumed to be 10 €/tonruck/km for a truck with a loading capacity of 25 t. Table 3-5 shows the selected dry matter (DM) content for the transported PS and PHA-rich biomass.

Table 3-5: DM content for the transported PS and PHA rich biomass

transport related information	
truck load (tons)	25
DM-content local produced PS	3%
DM-content transported PS	5%
DM-content dewatered PHA rich biomass	30%
DM-content dried PHA rich biomass	90%
specific PS production DM (g/PE/d)	35
transport cost (€/truck/km)	10

3.3 Mass balance

The mass balance for PHA production and processing was adopted from (Khan, 2021) for the case with 3% DM content in PS input.

When the input PS are extern from other plants, 5% DM-content is assumed. In this case, the mass balance for PHA production and processing is adjusted based on the assumption that PHA-rich biomass and PHA production amount with the same amount of DM input is constant. Table 3-15 shows the yield coefficient derived from the mass balance used in (Khan, 2021).

Table 3-6: Yield coefficient

Yield	
tons PHA-rich biomass DM/tons PS,input DM	0.36
tons PHA DM / tons PHA-rich biomass DM	0.56

4 Cost analysis and initial concepts

4.1 Cost in dependence of size and number of involved plant

According to (Khan, 2021), a PHA production of 5,000 ton/y with a total annual of 26,113,152 €/y results in a minimum selling price lower than market price. For that, a total amount of PS-input of around 25,000 t/y DM is required, which correspond to around 2,000,000 PE with a specific PS-production of 35 g/PE/d DM. Since a single WWTP with this capacity is rare, the decentralized concept with PS or PHA-rich biomass transport is more practical.

In Figure 4-2 and Figure 4-2, the specific cost for construction as well as operation a PHA-Enrichment system in dependence of the scale given in PE with 3% DM and 5% DM in PS-input is presented.

The cost function shows a higher specific cost for PHA-Enrichment in a small scale resulting from a higher CAPEX and constant labor cost independent of system scale. This indicates that the installation of PHA-Enrichment system should be as centralized as possible.

Furthermore, with the increasing of DM content in PS-input, the required size of system is reduced with the same amount of PHA-rich biomass produced, which lead to a significant reduction of CAPEX and OPEX with regard to the required material resource.




Figure 4-1: specific cost for construction as well as operation a PHA-Enrichment system with a DM content in PS-input of 3 %




Figure 4-2: specific cost for construction as well as operation a PHA-Enrichment system with a DM content in PS-input of 5 %

Figure 4-3 and Figure 4-4 shows the specific cost for the PHA-extraction and PHA-compounding system with regard to the scale given in PE. Similar to PHA-enrichment system, a less specific cost can be achieved with a larger scale system.




Figure 4-3: specific cost for the PHA-extraction system




Figure 4-4: specific cost for the PHA-compounding system

Transport cost depends on the transport amount and distance. Whether a larger plant within a larger distance from central plant for the PS supply or several smaller near plants should be chosen should be assessed with specific data.

4.2 Concepts

The considered concepts can roughly be divided into two types. For the first type, the primary sludge produced in different WWTPs are transported to a central plant, while for the second type, the primary sludge produced in each WWTP are directly used for the production of PHA-rich biomass in the local constructed PHA-enrichment system and the produced PHA-rich biomass are transported to central plant for the further PHA production.

In consideration of the required primary sludge amount, WWTPs close to the single selected central plant may not be able to provide sufficient primary sludge. When the WWTPs not close to the central plant are involved, the transport cost will increase. Therefore, besides the concept, in which only one central plant receiving the primary sludge for the PHA-production is planned, another concept, in which one decentral PHA-enrichment system receiving primary sludge and providing PHA-rich biomass and one central plant receiving both primary sludge and PHA-rich biomass are planned. Through decentralization of the PHA-enrichment system, WWTPs near both the central plant and decentral PHA-enrichment system can be regarded as the primary sludge suppliers, WWTPs within a long distance from either central plant or decentral PHA-enrichment system probably don't need to be considered and the transport cost then may be saved. However, with the extra decentralized PHA-enrichment system, the size of two PHA-enrichment system will be smaller, which lead to higher specific cost for construction of PHA-enrichment system as well as higher total cost. Furthermore, the transportation of PHA-rich biomass also costs extra.

Since the primary sludge transport is not really practical for some regions due to e.g. high water content in primary sludge, concepts with decentralized PHA-enrichment system are considered, so that the produced PHA-rich biomass with less amount can be transported rather than primary sludge. Depending on the size of the decentralized PHA-enrichment systems, dryer for the PHA-rich biomass drying is also considered to be installed with the decentralized PHA-enrichment systems. Therefore, besides the concept, in which only dewatered PHA-rich biomass produced from decentralized PHA-enrichment systems is transported to the central plant for further extraction and compounding, another concept, in which dewatered PHA-rich biomass produced from some decentralized PHA-enrichment systems is firstly dried and then transported, is considered.

In Table 4-1, advantages and disadvantages of concepts are summarized. As the concepts with PHA-rich biomass transport require decentralized PHA-enrichment system, which leads to higher specific investment cost, the investment cost for these concepts will generally higher than the investment cost for concepts with primary sludge transport. However, since the required amount of primary sludge is much higher than the required amount of PHA-rich biomass, the transport cost for concepts with primary sludge transport will be higher than that for concepts with PHA-rich biomass transport.

Table 4-1: Advantages and disadvantages of concepts

	primary sludge transport		PHA rich biomass transport		Remarks
	One central plant	One central plant One decentral PHA-enrichment system	dewatered PHA rich biomass transport	dried PHA rich biomass transport	
Specific investment cost	++	+	-	--	
Transport cost	--	-	+	++	
Free capacity of original digesters	central plant: -- PS supplier: +	central plant: - PS supplier: + PHA-rich biomass supplier:-	central plant: + PHA-rich biomass supplier:+	central plant: + PHA-rich biomass supplier:+	assuming that digesters exist in all plants
Biogas production	central plant: ++ PS supplier:--	central plant: + PS supplier: -- PHA-rich biomass supplier:+	central plant: - PHA-rich biomass supplier:-	central plant: - PHA-rich biomass supplier:-	
Nitrogen load in reject water from digesters	central plant: -- PS supplier:+	central plant: - PS supplier: + PHA-rich biomass supplier:-	central plant: + PHA-rich biomass supplier:+	central plant: + PHA-rich biomass supplier:+	

For the plants receiving the primary sludge for PHA-enrichment, the load of the digester increase, which also lead to a higher nitrogen load in reject water. When the capacity of the digester is insufficient, the construction of new digester may also be necessary. However, due to the increased load, more biogas production can be expected in these plants.

For the plants providing primary sludge for PHA-enrichment system, the inflow of local digester is reduced, which leads to a lower nitrogen load in reject water. The freed capacity of digesters can be filled with e.g. co-substance with better degradability. Otherwise, the biogas production in these plants will decline.

For the plants with decentral PHA-enrichment system and only local primary sludge as inflow, since a part of primary sludge is fermented for PHA-production, the load of the original digester and the produced biogas amount decline.

5 Region-specific study

To create an analysis of ideal locations to place both decentralized enrichment plants and centralized PHA production plants, tables containing coordinates and all descriptive and numerical data are transformed to be visualized as point data on a map in ArcGIS. ESRI ArcGIS pro offers several toolboxes to solve network optimization problems. The data can then be used to calculate routes and weighted values, using the different networking tools.

The Location-Allocation tool chooses the best locations from a set of input locations, and a selected optimization method. Given a set of candidate points and supply points it generates the optimal location(s) for one or multiple facilities, minimizing the total distance or the weighted distance. The solution is the scenario that allocates the most supply to facilities and minimizes overall distance between supply points and facilities. The output includes the optimal locations for facilities, demand (or supply) points associated with their assigned facilities and lines connecting supply points to their facilities. The lines are depicted as straight lines, but a cloud based infrastructure network is used to calculate actual transport distances from supply points towards the facilities, that is used to calculate the complete distance term per supply point.

In addition, the location-allocation solver has options to solve a variety of location problems such as:

- minimizing weighted impedance (minimize the total weight multiplied by the total distance)
- maximize capacity (trying to fulfill the maximum capacity set by the user)
- maximizing coverage (aims to maximize the spread of the different locations)
- achieving a target market share

Independent on the location problem, the cut-off distance can be set, this is the maximum distance allowed to be in between the facility and a demand point. Demand-points are all the WWTP that need to be included in the analysis. All demand-points get transported towards Facilities, facilities are bigger WWTP's that are eligible to serve as a collection point for sludge and a PHA-extraction facility. The cut-off distance has been used to approximate a PE of 2,000,000, the pre-determined minimal required capacity for a technical and financial viable PHA production plant. Further information about the location allocation tool can be found through the following [link](#).

For three different regions, Scotland, Saarland (Germany), Germany and Ireland, different variants with specific arrangement are developed based on the concepts mentioned in Chapter 4.2.

Primary sludge has a dry matter content of 3 to 5%, consequentially the other 97 to 95% is water. Due to this fact, a minimum capacity of demand points was set at 50,000 PE. The size would provide the financial opportunity to at least de-water the sludge before transportation. For the facility receiving the de-watered sludge, a dryer is necessary. Dryers are existing and feasible in bigger facilities with 300,000 PE or more.

For all the facilities and demand points (except Saarland), the assumption is that every WWTP with more than 300,000 PE will transport dried primary sludge, all smaller WWTP's will transport de-watered sludge.

5.1 Scotland

In Scotland, there are 153 WWTPs in total with a capacity of 7,698,322 PE. Among them, 30 WWTPs have capacity larger than 50,000 PE and 7 WWTPs have a capacity larger than 300,000 PE, shown in figure 5-1.




Figure 5-1: GIS map of all participating WWTPs in Scotland

Three separate locations were analysed as potential location for a PHA production facility, which are Aberdeen, Glasgow and Edinburgh.

5.1.1 Aberdeen

During the analysis, it was concluded that with the limitation of at least 50,000 PE per demand point, Aberdeen is not a viable location for a PHA extraction plant. Even with a cut-off distance of 160km Aberdeen only reaches a total amount of 864,172 PE, whereas 2,000,000 PE is required. Therefore, the Aberdeen scenario was not further analyzed and discarded as viable option.

5.1.2 Glasgow

For Glasgow, a cut-off distance was used to approach a PE of 2,000,000 as closely as possible. Where for Glasgow a selection was made by the algorithm between the two biggest facilities; Dalmuir PFI and Shieldhall S.T.W, with a cut-off distance off 45km, a sum of 2,636,978 PE was reached. The analysis is visualized in figure 5-2 and the outcomes are shown in table 5-1.

Glasgow transportation




Figure 5-2: Chosen scenario after location-allocation analysis for Glasgow

Table 5-1: Participating facilities in Glasgow scenario

GLASGOW		
Name	Weight (Load entering PE)	Total_Kilometers
DALMUIR PFI - DALMUIR WWTW - SHIELDHALL S.T.W.	581,220	11.32
SHIELDHALL S.T.W. - SHIELDHALL S.T.W.	563,713	0.00
MEADOWHEAD W.W.T. SERVICE - SHIELDHALL S.T.W.	332,371	42.09
DALDOWIE S.T.W. - SHIELDHALL S.T.W.	317,927	16.98
DALMARNOCK S.T.W. - SHIELDHALL S.T.W.	232,840	9.87
LAIGHPARK S.T.W. - SHIELDHALL S.T.W.	126,440	7.00
INVERCLYDE W.W.T. SERVICE - SHIELDHALL S.T.W.	87,914	40.25
ERSKINE S.T.W. - SHIELDHALL S.T.W.	83,015	6.82
STEVENSTON W.W.T.SERVICE - SHIELDHALL S.T.W.	82,813	42.51
HAMILTON S.T.W. - SHIELDHALL S.T.W.	63,430	22.71
ARDOCH S.T.W. - SHIELDHALL S.T.W.	61,219	23.22
PHILIPSHILL S.T.W. - SHIELDHALL S.T.W.	54,258	15.97
ALLERS S.T.W. - SHIELDHALL S.T.W.	49,818	19.90

The load entering PE is the amount of people equivalents that enter the WWTP, the total kilometres is the amount of kilometres between the chosen facility and the specific demand point.

As visible in table 5-1, the chosen location is Shieldhall, despite the fact that Shieldhall is slightly smaller in capacity than Dalmuir. However, due to location optimization, the software calculated the above scenario to be most efficient.

Hamilton is shown in red, because it is overlapping with the scenario for Edinburgh as explained in next paragraph.

It needs to be taken into account that the total kilometres does not equal the amount of kilometres that needs to be driven when implementing this scenario in practice. The total amount of transport is dependent on the weight too. Therefore, to calculate the total amount of kilometres, the PE should be multiplied by the weight of either the dry-matter or de-watered sludge (dependent on the process), followed by dividing that number through the estimated capacity of a truck; 25 ton. These calculations will be shown in chapter 6 and 7.

5.1.3 Edinburgh

For Edinburgh, even with a cut-off distance of 70km, only a sum of 1,479,458 PE was reached, these results are shown in figure 5-3 and Table 5-2. Within this cut-off distance, one of the water treatment facilities, HAMILTON S.T.W, overlaps with the Glasgow scenario selection. However, HAMILTON S.T.W., only accounts for 63,430 PE and can be easily missed from the Glasgow scenario which includes way more than 2 million PE. Then again, there might be a possibility for the Edinburgh scenario to reach 2 million PE when Perth, Hatton and Aberdeen (not visible figure 5-3 except for Perth) could contribute by boat. They would respectively add 100,353, 240,825 and 289,584 PE, ensuring a total PE of 2,110,220.

Edinburgh transportation




Figure 5-3: Chosen scenario after location-allocation analysis for Edinburgh

Table 5-2: Participating facilities in Glasgow scenario

EDINBURGH		
Name	Weight (Load entering PE)	Total_Kilometers
EDINBURGH, SEAFIELD WWTW - EDINBURGH, SEAFIELD WWTW	764,659	0.00
LEVEN VALLEY, LEVENMOUTH WWTW - EDINBURGH, SEAFIELD WWTW	172,355	60.18
EAST CALDER WWTW - EDINBURGH, SEAFIELD WWTW	115,185	26.08
DALDERSE WWTW - EDINBURGH, SEAFIELD WWTW	91,701	46.51
DUNFERMLINE STW - EDINBURGH, SEAFIELD WWTW	83,507	24.95
STIRLING WWTW - EDINBURGH, SEAFIELD WWTW	78,108	62.26
HAMILTON S.T.W. - EDINBURGH, SEAFIELD WWTW	63,430	67.00
KIRKCALDY WWTW - EDINBURGH, SEAFIELD WWTW	61,055	46.85
KINNEIL KERSE WWTW - EDINBURGH, SEAFIELD WWTW	49,458	38.65

As visible in table 5-2, the chosen location for the PHA production facility would be at Edinburgh Seafeld WWTP. In total 8 other WWTPs would contribute to this scenario with a possible addition of Perth, Hatton and Aberdeen as mentioned previously. Again, the table does not show the total transport kilometres for this scenario.

5.2 Saarland (region Germany)

The Saarland region in Germany is a relatively small area. The total capacity of 60 WWTPs in Saarland are 1,477,900 PE. The largest WWTP is WWTP Burbach with 200,000 PE. Only 9 WWTPs have capacity above 50,000 PE, as show in figure 5-4.




Figure 5-4: GIS map of all participating WWTPs in Saarland (Germany)

Within the original assignment, Saarland in Germany was one of the set areas to assess the feasibility of a PHA production plant. Initial research showed that within the region of Saarland too little PE is available to create a PHA production plant. To check how it would be feasible to have a PHA production facility in the region (or close surroundings) of Saarland, an analysis was performed including some additional WWTPs that are outside the borders of Saarland.

For this analysis, only WWTPs with 100,000 PE or more could be chosen as candidate point, all WWTPs above 50,000 PE (from all over Germany) were added as demand points. As the function maximize capacity was used with a cap of 3,500,000 PE, the cut-off distance was used to approach 2,000,000 PE afterwards. This cut-off distance ended up to be 125 km, providing a PE of 2,214,984. The results of this analysis are shown in figure 5-5 and table 5-3.

Table 5-3: Participating facilities in Saarland scenario

Saarland (Germany)				
Name	Weight	TotalWeighted_Kilometers	Total_Kilometers	Total_TruckTravelTime
Worms - Kaiserslautern	179,000	11,233,945	62.76	64.56
Neustadt ZKA - Kaiserslautern	67,500	3,133,522	46.42	63.93
Landau - Kaiserslautern	57,686	3,471,606	60.18	76.69
Ludwigshafen - BASF AG - Kaiserslautern	285,000	15,983,972	56.08	49.94
Trier Hauptklärwerk - Kaiserslautern	142,740	15,472,702	108.40	109.14
Kläranlage Mannheim - Kaiserslautern	517,255	31,181,895	60.28	58.76
KA WELLESWEILER - Kaiserslautern	61,700	2,866,154	46.45	52.52
KA JÄGERSFREUDE - Kaiserslautern	52,860	3,541,488	67.00	72.81
KA BURBACH - Kaiserslautern	158,350	12,281,759	77.56	90.39
KA BREBACH - Kaiserslautern	133,300	9,048,013	67.88	62.35
KA HOMBURG - Kaiserslautern	68,550	2,876,949	41.97	49.73
KA SAARLOUIS - Kaiserslautern	75,150	6,675,394	88.83	80.93
KA ENSDORF - Kaiserslautern	55,350	4,872,190	88.03	85.63
KA VÖLKLINGEN - Kaiserslautern	67,000	5,650,412	84.33	95.94
KA MERZIG - Kaiserslautern	50,650	5,322,741	105.09	96.90
Kaiserslautern - Kaiserslautern	134,832	-	0.00	0.00
Pirmasens-Blümelstal - Kaiserslautern	54,594	2,105,118	38.56	47.28
Zweibrücken - Kaiserslautern	53,467	2,753,118	51.49	60.06
Bad Kreuznach - Kaiserslautern	99,061	6,263,309	63.23	76.17

As visible in table 5-3, the WWTP in Kaiserslautern with 134,832 PE was the chosen location for the PHA production facility. Kaiserslautern does not lay within Saarland, but relatively close to the borders of it. A total of 18 additional WWTPs are required to make this scenario work. As mentioned, a relative big cut-off distance was required. Again, table 5-3 does not show the total transport kilometres for this scenario.

5.3 Germany

Germany has a total of 3810 WWTPs and a sum of 118,304,154 PE. There are 50 WWTPs with a capacity higher than 300,000 PE which account together for 39,074,112 PE. Furthermore, 434 WWTPs have a capacity over 50,000 PE. The map showing all WWTPs in Germany is shown in figure 5-6.




Figure 5-6: GIS map of all participating WWTPs in Germany

Additionally to the analysis for Saarland, an analysis was also performed for the whole of Germany. The limit was set to 8 PHA production facilities with a cut-off distance of 45 kilometres for WWTPs to supply dried primary sludge. This means for this analysis only WWTPs with 300,000 PE or more were part of this analysis. A maximum of 3,500,000 PE was set per potential PHA production facility. The outcomes of the analysis is shown in figure 5-7.

Germany possible locations




Figure 5-7: Chosen scenario after location-allocation analysis for Germany

Table 5-4: The 8 possibilities for PHA production facilities in Germany

Germany 300.000 PE or more only							
Name	FacilityType	Weight	DemandCount	DemandWeight	Capacity	Total_Kilometers	TotalWeighted_Kilometers
Kläranlage Mannheim	Chosen	517,255	6	3,266,266	3,500,000	354.31	193,159,748.51
Augsburg	Chosen	500,997	4	2,635,853	3,500,000	221.66	157,044,753.87
Neuss-Ost	Chosen	389,233	7	3,496,169	3,500,000	205.04	105,945,553.18
Bottrop	Chosen	1,150,304	4	3,392,448	3,500,000	159.72	129,374,553.42
Emscherkläranlage	Chosen	1,830,977	3	2,521,237	3,500,000	31.57	10,874,830.23
Klärwerksverbund Köhlbrandhöft Dradenau	Chosen	2,500,000	2	3,391,439	3,500,000	29.95	26,700,066.19
Ruhleben	Chosen	1,901,188	2	2,742,277	3,500,000	25.77	21,671,766.14
Waßmannsdorf	Chosen	2,023,000	1	2,023,000	3,500,000	0.00	0

Table 5-4 is showing the outcomes for Germany region where 8 potential PHA facilities were picked. All of the 8 outcome possibilities have a PE higher than 2,000,000 and one of them even has 0km driven, meaning to be self-supporting. Of course there are some other WWTPs in Germany with a PE above 2,000,000 that could already install a self-supporting PHA production facility, however these are not mentioned in this assessment since these speaks for itself.

Table 5-4 shows the different facilities, their own weight (in PE), the DemandCount which stands for the amount of demand-points from which dried primary sludge must be collected (including itself), DemandWeight which is the combined weight (in PE) of both the facility and the demand points. The capacity is the variable that was set as maximum PE per PHA production facility and total weighted kilometres which is weight*kilometres.

5.4 Ireland

Ireland has a total of 163 WWTPs with a total capacity 5,447,495 PE of which only Dublin and Cork have a PE over 300,000. Furthermore, Ireland only has 18 WWTPs with a PE over 50,000, with a total capacity of 3,751,840. All of this is shown in figure 5-8.




Figure 5-8: GIS map of all participating WWTPs in Ireland

Since Ireland has only 2 facilities with a capacity over 300,000 PE, consequentially only 2 facilities were set as potential candidate points. Using the maximize capacity setting, only Dublin was able to surpass the required 2,000,000 PE, while Cork was only able to reach 1,088,133. Since the setting tried to gain maximal capacity, Cork was assumed not to be a viable location for a PHA production plant. The next step entailed setting a cut-off distance for Dublin to approach the 2,000,000 PE as closely as possible, consequentially minimizing demand points and total kilometres driven. The analytical results are shown in figure 5-9.

Ireland: Dublin facility




Figure 5-9: Chosen scenario after location-allocation analysis for Ireland

Table 5-5: Participating facilities in Saarland scenario

Ireland Name	Weight	TotalWeighted_Kilometers	Total_Kilometers
Ringsend Waste Water Treatment Plant - Ringsend Waste Water Treatment Plant	1,640,000	-	0.00
Shanganagh Waste Water Treatment Plant - Ringsend Waste Water Treatment Plant	186,000	3,124,601.59	16.80
Leixlip Waste Water Treatment Plant - Ringsend Waste Water Treatment Plant	150,000	3,167,669.37	21.12
Osberstown Waste Water Treatment Plant - Ringsend Waste Water Treatment Plant	80,000	3,169,021.69	39.61
Swords Wastewater Treatment Plant - Ringsend Waste Water Treatment Plant	60,000	1,104,465.46	18.41
Balbriggan Waste Water Treatment Plant - Ringsend Waste Water Treatment Plant	70,000	2,436,593.64	34.81
Portrane Waste Water Treatment Plant - Ringsend Waste Water Treatment Plant	65,000	1,658,235.33	25.51

Table 5-5 is showing the outcomes for the Ireland scenario in which Ringsend WWTP in Dublin was chosen as PHA production location, ending up with 2,251,000 PE from 6 demand points within a range of 40km.

5.5 Conclusions GIS analysis

Due to the costs connected to transport, the less kilometers driven the better. For Scotland, Aberdeen does not seem to be a viable location transport wise, while Edinburgh is optional but dependent on shipping feasibility. The best and only proven viable location in Scotland is Glasgow.

For Saarland, within the province there is not enough PE to build a PHA production facility. However, when including the surroundings, 18 demand-points together with Kaiserslautern as chosen location, come to a PE of 2,314,045. Despite that, those 18 demand-points have an average of 64 km distance to the facility. Although those kilometers are not weighted, relatively a lot of transport is required.

Germany as a country has 8 very viable options next to the WWTPs that could be self-supporting already. All of these are suitable for a PHA extraction facility, also since all of the demand points have 300,000 PE or higher and therefore only dried primary sludge will be transported instead of also dewatered primary sludge.

For Ireland, Dublin is the only viable location. Since it is the biggest facility within Ireland, the potential is there when 6 demand points contribute bringing their sludge towards the facility in Dublin. However, the distance towards these facilities is relatively high, then again, most of the required sludge is already at Dublin itself.

Concluding, from the original research locations (Scotland, Saarland and Ireland), Glasgow in Scotland is the most viable location in its region based on the GIS results. However, since Saarland was not able to gain enough PE by itself, Germany as a country was also analyzed. Within Germany, there are several options that would (transport wise) even be more aligned, especially since all demand-points taken into account are over 300,000 PE and thus would only need to transport dried primary sludge.

6 Region-specific study – Cost analysis

6.1 Basics for the calculation of the sludge amounts

For the cost analysis the following sludge streams are considered (see also Table 3-5 and Table 3-6):

- primary sludge with a DM content of 3% and a specific sludge production from 35 g/PE/d, if it is used directly at the WWTP for the PHA enrichment facility
- thickened primary sludge with a DM content of 5% and a specific sludge production from 35 g/PE/d, if it is transported to a central plant
- dewatered PHA-rich-biomass with a DM content of 30% and dried PHA-rich-biomass with a DM content of 90% and a yield of 0,36 tons $DM_{\text{PHA-rich biomass}}$ per tons $DM_{\text{PS,input}}$

The sludge is transported with a truck with a capacity of 25 tons.

6.2 Scotland

The results of the GIS tool show that the Glasgow region has the shortest distances between the central PHA extraction plant and the decentralized plants. Therefore 6 potentially suitable variants for PHA-production were investigated for the Glasgow region. One of them are with primary sludge transport to Dalmuir STP, while the rest are with PHA-rich biomass transport to Shieldhall STP in Glasgow.

6.2.1 Primary sludge transport

Central

In this variant, the central plant with PHA-enrichment system, PHA-extraction system and compounding system is set in Dalmuir WWTP with a physical capacity of 581,220 PE. Ten other WWTPs within 40 km from Dalmuir WWTP are selected to provide primary sludge. The physical loading, primary sludge amount of central plant and primary sludge suppliers and distance from primary sludge suppliers to central plant are summarized in Table 6-1. The transported primary sludge amount sums up to 419.176 tons/y with a DM content of 5 %. The total truck kilometres amount to 313,178 km/y. According to the mass balance, the PHA production amount of this variant is estimated as 5,610 tons/y.




Figure 6-1: GIS-Results variant 1.1: Primary sludge transport from 10 decentral plants and one central plant




Figure 6-2: Variant 1.1: Primary sludge transport from 10 decentral plants and one central plant

Table 6-1: involved WWTPs in Variant 1.1

	WWTP	Physical loading (PE)	PS (tons/y)	PS DM (tons/y)	frequency (1/y)	truck kilometers (f*km/a)	Distance to central plant (km)
Central plant PS with a DM content of 3% for PS							
0	DALMUIR WWTW	581,220	247,503	7,425	-	-	-
Primary sludge supplier with a DM content of 5%							
1	SHIELDHALL S.T.W.	563,713	144,029	7,201	5,761	60,644	10.5
2	DALDOWIE S.T.W.	317,927	81,230	4,062	3,249	82,625	25.4
3	DALMARNOCK S.T.W.	232,840	59,491	2,975	2,380	43,598	18.3
4	LAIGHPARK S.T.W.	126,440	32,305	1,615	1,292	22,533	17.4
5	INVERCLYDE W.W.T. SERVICE	87,914	22,462	1,123	898	33,236	37.0
6	ERSKINE S.T.W.	83,015	21,210	1,061	848	13,164	15.5
7	HAMILTON S.T.W.	63,430	16,206	810	648	20,204	31.2
8	ARDOCH S.T.W.	61,219	15,641	782	626	8,911	14.2
9	PHILIPSHILL S.T.W.	54,258	13,863	693	555	13,692	24.7
10	ALLERS S.T.W.	49,818	12,728	636	509	14,571	28.6
	Sum Primary sludge supplier	1,640,574	419,167	20,958		313,178	

Decentral

In this variant, PHA-enrichment system, PHA-extraction system, and compounding system is set in Shieldhall STW with a physical capacity of 563,713 PE. Besides that, a decentral PHA enrichment plant is set in Edinburgh WWTP with a physical capacity of 764,659 PE. Four and two other WWTP are separately selected to provide primary sludge for central plant and decentral PHA enrichment plant. The dewatered PHA-rich biomass produced in decentral PHA enrichment plant in Edinburgh WWTP will be transported to central plant in Shieldhall STW for further extraction and compounding process. The physical loading, primary sludge amount of selected WWTPs, the distance from primary sludge suppliers to receivers and from decentral PHA enrichment plant to central plant are summarized in Table 6-2. The transported primary sludge amount sums up to 312,274 t/y with a DM content of 5 %. The total truck kilometres for primary sludge transport can be reduced due to the decentral PHA enrichment plant to 157,583 km/y. Furthermore, the transport of the dewatered PHA-rich biomass (14,593 t/y) from the decentral PHA enrichment plant has to be considered. The transport kilometres for the dewatered PHA-rich biomass sums up to 50.203 km/y. According to the mass balance, the PHA production amount of this variant is estimated as 6,440 t/a.




Figure 6-3: GIS-Results variant 1.2: Primary sludge transport from 6 decentral plants to one central plant and one decentral PHA enrichment plant




Figure 6-4: Variant 1.2: Primary sludge transport from 6 decentral plants to one central plant and one decentral PHA enrichment plant

Table 6-2: involved WWTPs in variant 1.2

	WWTP	Loading entering (PE)	PS (tons/y)	PS DM (tons/y)	PHA-rich biomass (tons/y)	frequency (1/y)	truck kilometers (f*km/a)	Distance to central plant (km)
Central plant with a DM content of 3% for PS								
1	SHIELDHALL S.T.W.	563,713	240,048	7,201				-
Decentral PHA-enrichment plant with a DM content of 3% for PS								
2	EDINBURGH, SEAFIELD	764,659	325,617	9,769	14,593	584	50,203	86.0
Primary sludge supplier for central plant, 5% DM-content								
1.1	DALMUIR PFI - DALMUIR WWTP	581,220	148,502	7,425		5,940	67,220	11.3
1.2	DALMARNOCK S.T.W.	232,840	59,491	2,975		2,380	23,483	9.9
1.3	LAIGHPARK S.T.W.	126,440	32,305	1,615		1,292	9,053	7.0
1.4	ERSKINE S.T.W.	83,015	21,210	1,061		848	5,783	6.8
Primary sludge supplier for decentral PHA-enrichment plant, 5% DM-content								
2.1	EAST CALDER WWTP	115,185	29,430	1,471		1,177	30,703	26.1
2.2	DUNFERMLINE STW	83,507	21,336	1,067		853	21,296	25.0
	Sum PS supplier	1,222,207	312,274	15,614			157,538	

6.2.2 PHA rich biomass transport

Based on the information from Scottish Water, the primary and secondary sludge from WWTPs with sludge production less than 1,000 tons/a DM will be locally used. Therefore, assuming that the daily primary and secondary sludge production per population equivalent is 55 g/(PE*d) DM, WWTPs with a load less than 50,000 PE are not considered for PHA-production. Furthermore, primary sludge and secondary sludge are thickened and transported together in Scotland. Therefore, the separate primary sludge transport required in variant 1.1 and 1.2 isn't purposeful.

For this reason, variants with decentralized PHA enrichment plants and PHA-rich biomass transport are being developed for Scotland. In consideration of the common throughput of dryers used for sewage sludge drying, in some variants, the dewatered PHA-rich biomass is planned to be dried before being transported.

Dewatered PHA-rich biomass transport

For the first two variants only dewatered PHA-rich biomass produced from the decentral PHA-enrichment plants are transported to the central plant.

In variant 2.1, seven WWTPs are chosen to be the site for the decentral PHA-enrichment system, which are all within the distance of 23km from central plant and with an load over 54,000 PE (see Figure 6-5 and Figure 6-6)

In variant 2.2, four WWTPs with entering loading below 230,000 PE in variant 2.1 are replaced by the WWTP named MEADOWHEAD W.W.T. with an entering loading of 332,371PE, which is around 42 km away from the central plant (see Figure 6-7 and Figure 6-8).

In Table 6-3 and Table 6-4, the entering loading, primary sludge amount of selected WWTPs, the distance from dewatered PHA-rich biomass suppliers to central plant in variant 2.1 and variant 2.2 are separately summarized. The produced primary sludge amount in each plant is estimated on the basis of the entering loading and two assumptions that the specific primary sludge production is 35gDM/PE/d and the DM-content in primary sludge is 3%. The total truck kilometres for dewatered PHA-rich biomass transport results for variant 2.1 to 10,926 km/y for variant 2.1 and 17,125 km/y for variant 2.2.

According to the mass balance, a PHA production of 5,107 t/y can be expected with variant 2.1, while the PHA production amount of variant 2.2 is estimated to be 5,120 t/y.




Figure 6-7: GIS-results: variant 2.2 with one central plant and 4 decentral plants providing dewatered PHA-rich biomass




Figure 6-8: variant 2.2 with one central plant and 4 decentral plants providing dewatered PHA-rich biomass

Table 6-3: involved WWTPs in variant 2.1

	WWTP	Loading entering (PE)	PS (tons/y)	PS DM (tons/y)	PHA-rich biomass (tons/y)	frequency (1/y)	truck kilometers (f*km/a)	Distance to central plant (km)
Central plant								
0	SHIELDHALL S.T.W.	563,713	240,048	7,201				-
Dewatered PHA-rich biomass supplier								
1	DALMUIR WWTW	581,220	247,503	7,425	8,805	352	3,985	11.3
2	DALDOWIE S.T.W.	317,927	135,384	4,062	4,816	193	3,270	17.0
3	DALMARNOCK S.T.W.	232,840	99,151	2,975	3,527	141	1,392	9.9
4	LAIGHPARK S.T.W.	126,440	53,842	1,615	1,915	77	537	7.0
5	ERSKINE S.T.W.	83,015	35,351	1,061	1,258	50	343	6.8
6	HAMILTON S.T.W.	63,430	27,011	810	961	38	873	22.7
7	PHILIPSHILL S.T.W.	54,258	23,105	693	822	33	525	16.0
	Sum PHA-rich biomass supplier	1,459,130	621,346	18,640	22,104		10,926	

Table 6-4: involved WWTPs in variant 2.2

	WWTP	Loading entering (PE)	PS (tons/y)	PS DM (tons/y)	PHA-rich biomass (tons/y)	frequency (1/y)	truck kilometers (f*km/a)	Distance to central plant (km)
Central plant								
0	SHIELDHALL S.T.W.	563,713	240,048	7,201				-
Dewatered PHA-rich biomass supplier								
1	DALMUIR WWTW	581,220	247,503	7,425	8,805	352	3,985	11.3
2	MEADOWHEAD W.W.T.	332,371	141,535	4,246	5,035	201	8,476	42.1
3	DALDOWIE S.T.W.	317,927	135,384	4,062	4,816	193	3,270	17.0
4	DALMARNOCK S.T.W.	232,840	99,151	2,975	3,527	141	1,392	9.9
	Sum PHA-rich biomass supplier	1,464,358	623,572	18,707	22,183		17,125	

Combination of dried and dewatered PHA-rich biomass transport

Since in variant 2.2, three of four WWTPs chosen to be the site for decentral PHA enrichment plant have the entering loading more than 300,000 PE, in variant 3.1, to install 3 dryers separately in these three decentral plants are considered as shown in Figure 6-9 and Figure 6-10.




Figure 6-9: Gis-results variant 3.1 with one central plant, 1 decentral plants providing dewatered PHA-rich biomass and 3 decentral plant providing dried PHA-rich biomass




Figure 6-10: variant 3.1 with one central plant, 1 decentral plants providing dewatered PHA-rich biomass and 3 decentral plant providing dried PHA-rich biomass

In Table 6-5, the entering loading, primary sludge amount of selected WWTPs, the distance from dewatered as well as dried PHA-rich biomass suppliers to central plant in variant 3.1 are separately summarized. The produced primary sludge amount in each plant is also estimated on the basis of the entering loading and the assumed specific primary sludge production of 35gDM/PE/d as well as the assumed DM-content of 3% in primary sludge. The total truck kilometres for dried and dewatered PHA-rich biomass transport results for variant 3.1 to 6,636 km/y.

Table 6-5: involved WWTPs in variant 3.1

	WWTP	Loading entering (PE)	PS (tons/y)	PS DM (tons/y)	PHA-rich biomass (tons/y)	frequency (1/y)	truck kilometers (t*km/a)	Distance to central plant (km)
Central plant								
0	SHIELDHALL S.T.W.	563,713	240,048	7,201				-
Dewatered PHA-rich biomass supplier								
1	DALMARNOCK S.T.W.	232,840	99,151	2,975	3,527	141	1,392	9.9
Dried PHA-rich biomass supplier								
2	DALMUIR WWTW	581,220	247,503	7,425	2,935	117	1,328	11.3
3	MEADOWHEAD W.W.T.	332,371	141,535	4,246	1,678	67	2,825	42.1
4	DALDOWIE S.T.W.	317,927	135,384	4,062	1,605	64	1,090	17.0
	Sum PHA-rich biomass supplier	1,464,358	623,572	18,707	9,746		6,636	

In order to have a concept with even less number of involved WWTPs, the largest WWTPs in Scotland named SEAFIELD WWTW in Edinburgh is considered in the variant 3.2, which has an entering loading of 764,659 PE and a distance of around 85km from the central plant. In consideration of the loading and distance, a dryer is also planned in this WWTP. Besides, two other decentral PHA-enrichment system are planned in this variant to provide the dewatered PHA-rich biomass for central plant as shown in Figure 6-11 and Figure 6-15.

A summary of the entering loading, estimated primary sludge amount of selected WWTPs, the distance from dewatered as well as dried PHA-rich biomass suppliers to central plant in variant 3.2 are shown in Table 6-6. The total truck kilometres for dried and dewatered PHA-rich biomass transport results for variant 3.2 to 18,544 km/y.




Figure 6-11: variant 3.2 with one central plant, 2 decentral plants providing dewatered PHA-rich biomass and 1 decentral plant providing dried PHA-rich biomass




Figure 6-12: variant 3.2 with one central plant, 2 decentral plants providing dewatered PHA-rich biomass and 1 decentral plant providing dried PHA-rich biomass

Table 6-6: involved WWTPs in variant 3.2

	WWTP	Loading entering (PE)	PS (tons/y)	PS DM (tons/y)	PHA-rich biomass (tons/y)	frequency (1/y)	truck kilometers (t*km/a)	Distance to central plant (km)
Central plant								
0	SHIELDHALL S.T.W.	563,713	240,048	7,201				-
Dewatered PHA-rich biomass supplier								
1	DALMUIR WWTW	581,220	247,503	7,425	8,805	352	3,985	11.3
2	DALMARNOCK S.T.W.	232,840	99,151	2,975	3,527	141	1,392	9.9
Dried PHA-rich biomass supplier								
3	SEAFIELD WWTW	764,659	325,617	9,769	3,861	154	13,166	85.2
	Sum PHA-rich biomass supplier	1,578,719	672,271	20,168	16,193		18,544	

6.2.3 Estimated cost

The costs for the individual plant components were derived on the basis of equation 1.1 and the costs determined in Table 3-1 for a 2,000,000 PE plant.

The estimated cost for variant 1.1 and 1.2 with primary sludge transport are 27,340,491 €/y and 32,878,624 €/y, which are lower than the cost of other variants. With regard to the PHA production amount, the specific costs are separately 4,874 €/ton PHA and 5,106 €/ton. The cost for variant 1.2 increased in comparison to variant 1.1 because of the higher CAPEX cost of the partially decentralised PHA-enrichment system. The lower transportcost can compensate the higher CAPEX cost. Since the transported primary sludge has a higher dry matter content of 5%, the inflow and throughput in variant 1.1 and 1.2 is lower than other variant, which lead to a lower specific OPEX cost excluding cost for transport, labour, maintenance, and insurance. The cost breakdown for variant 1.1 and 1.2 are shown in Table 6-7 and Table 6-8.

Table 6-7: Cost for variant 1.1

	WWTP	CAPEX (€/a)	OPEX (€/a)				Sum (€/a)
			OPEX excluding cost for transport, labor, maintainance, insurance	Transport cost	Labor and maintainance cost	Insurance cost	
Central plant							
0	DALMUIR WWTW	3,816,138	19,031,297	0	1,342,199	19,081	24,208,714
1-12	Primary sludge suppliers for central plant	0	0	3,131,777	0	0	3,131,777
Sum (€/a)		3,816,138	19,031,297	3,131,777	1,342,199	19,081	27,340,491
Specific cost (€/t PHA)		680	3.393	558	239	3	4.874

Table 6-8: Cost for variant 1.2

	WWTP	CAPEX (€/a)	OPEX (€/a)				Sum (€/a)
			OPEX excluding cost for transport, labor, maintainance, insurance	Transport cost	Labor and maintainance cost	Insurance cost	
Central plant							
1	SHIELDHALL S.T.W.	3,281,108	19,014,176	0	1,342,199	16,406	23,653,889
Decentral PHA-enrichment plant							
2	EDINBURGH, SEAFIELD	2,327,964	4,090,771	502,034	716,951	11,640	7,649,359
1.1 - 1.10	Primary sludge suppliers for central plant	0	0	1,055,386	0	0	1,055,386
2.1 - 2.3	Primary sludge supplier for decentral PHA-enrichment plant	0	0	519,990	0	0	519,990
Sum (€/a)							
Sum (€/a)		5,609,072	23,104,947	2,077,410	2,059,150	28,045	32,878,624
Specific cost (€/t PHA)		871	3,588	323	320	4	5,106

For variant 2.1, 2.2, 3.1 and 3.2, the estimated cost are from 31,811,048 €/a for variant 2.2 to 34,417,514 €/a for variant 2.1. In fact, the estimated cost for variant 2.2, 3.1 and 3.2 are in the same order of magnitude.

Variant 2.2 and variant 3.1 have the same WWTPs with the similar function involved. Only the dewatered PHA-rich biomass is transported in variant 2.2, while in variant 3.1, the dried PHA-rich biomass is transported. However, the estimated results shows that the reduced transport cost through drying the transported PHA-rich biomass in variant 3.1 can't offset the cost for extra dryer installation, therefore, the total cost for variant 3.1 is a little bit higher than that of variant 2.2.

The comparison of estimated cost for variant 2.1 and 2.2 shows that with eight WWTPs involved in total, the cost for the highly decentralised PHA-enrichment system plays the decisive role, even if the decentral PHA-enrichment system in variant 2.1 are all within the distance of 23km from central plant.

For variant 3.2, the highest cost for the PHA-rich biomass transport is determined due to the long distance for the dried PHA-rich biomass transport. However, since only 3 decentralised PHA-enrichment system with relatively large scale are planned and the PHA-production amount is the highest, the specific cost of 5,973 €/ton PHA is the lowest among all variants with PHA-rich biomass transport.

Table 6-9: Cost for variant 2.1

	WWTP	CAPEX (€/y)	OPEX (€/y)				Sum (€/y)
			OPEX excluding cost for transport, labor, maintainance, insurance	Transport cost	Labor and maintainance cost	Insurance cost	
Central plant							
0	SHIELDHALL S.T.W.	2,181,621	13,399,417	0	1,342,199	10,908	16,934,146
Dewatered PHA-rich biomass supplier							
1	DALMUIR WWTW	1,751,468	2,696,074	39,854	716,951	8,757	5,213,105
2	DALDOWIE S.T.W.	1,142,963	1,474,751	32,704	716,951	5,715	3,373,084
3	DALMARNOCK S.T.W.	917,859	1,080,062	13,923	716,951	4,589	2,733,385
4	LAIGHPARK S.T.W.	598,325	586,510	5,367	716,951	2,992	1,910,145
5	ERSKINE S.T.W.	446,246	385,077	3,428	716,951	2,231	1,553,934
6	HAMILTON S.T.W.	370,187	294,229	8,730	716,951	1,851	1,391,949
7	PHILIPSHILL S.T.W.	332,219	251,684	5,252	716,951	1,661	1,307,767
Sum (€/y)		7,740,890	20,167,805	109,258	6,360,856	38,704	34,417,514
Specific cost (€/ton PHA)		1.516	3.949	21	1.246	8	6.739

Table 6-10: Cost for variant 2.2

	WWTP	CAPEX (€/y)	OPEX (€/y)				Sum (€/y)
			OPEX excluding cost for transport, labor, maintainance, insurance	Transport cost	Labor and maintainance cost	Insurance cost	
Central plant							
0	SHIELDHALL S.T.W.	2,182,354	13,427,290	0	1,342,199	10,912	16,962,754
Dewatered PHA-rich biomass supplier							
1	DALMUIR WWTW	1,751,468	2,696,074	39,854	716,951	8,757	5,213,105
2	MEADOWHEAD W.W.T.	1,179,357	1,541,752	84,764	716,951	5,897	3,528,720
3	DALDOWIE S.T.W.	1,142,963	1,474,751	32,704	716,951	5,715	3,373,084
4	DALMARNOCK S.T.W.	917,859	1,080,062	13,923	716,951	4,589	2,733,385
Sum (€/y)		7,174,002	20,219,929	171,245	4,210,003	35,870	31,811,048
Specific cost (€/ton PHA)		1,401	3,949	33	822	7	6,213

Table 6-11: Cost for variant 3.1

	WWTP	CAPEX (€/y)	OPEX (€/y)				Sum (€/y)
			OPEX excluding cost for transport, labor, maintainance, insurance	Transport cost	Labor and maintainance cost	Insurance cost	
Central plant							
0	SHIELDHALL S.T.W.	2,142,144	12,629,072	0	1,342,199	10,711	16,124,126
Dewatered PHA-rich biomass supplier							
1	DALMARNOCK S.T.W.	917,859	1,080,062	13,923	716,951	4,589	2,733,385
Dried PHA-rich biomass supplier							
2	DALMUIR WWTW	1,795,729	3,072,796	13,285	925,367	8,979	5,816,156
3	MEADOWHEAD W.W.T.	1,211,007	1,757,180	28,255	925,367	6,055	3,927,865
4	DALDOWIE S.T.W.	1,173,782	1,680,818	10,901	925,367	5,869	3,796,737
Sum (€/y)		7,240,522	20,219,929	66,364	4,118,300	36,203	32,398,268
Specific cost (€/ton PHA)		1,414	3,949	13	804	7	6,328

Table 6-12: cost for variant 3.2

	WWTP	CAPEX (€/y)	OPEX (€/y)				Sum (€/y)
			OPEX excluding cost for transport, labor, maintainance, insurance	Transport cost	Labor and maintainance cost	Insurance cost	
Central plant							
0	SHIELDHALL S.T.W.	2,175,660	13,541,372	0	1,342,199	10,878	17,070,109
Dewatered PHA-rich biomass supplier							
1	DALMUIR WWTW	1,751,468	2,696,074	39,854	716,951	8,757	5,213,105
2	DALMARNOCK S.T.W.	917,859	1,080,062	13,923	716,951	4,589	2,733,385
Dried PHA-rich biomass supplier							
3	SEAFIELD WWTW	2,180,578	4,042,602	131,658	925,367	10,903	7,291,108
Sum (€/y)		7,025,566	21,360,111	185,435	3,701,468	35,128	32,307,708
Specific cost (€/ton PHA)		1,299	3,949	34	684	6	5,973

6.2.4 Recommendation

In Table 6-13, the estimated cost for all variants are summarized. Based on estimated results, the variant 1.1 and 1.2 with primary sludge transport shows the least cost requirement. However, due to the current operation condition in WWTPs in Scotland, the operator Scottish Water would like to avoid primary sludge transport. Variant 1.1 and 1.2 are therefore not recommended.

Among the variants with PHA-rich biomass transport, variant 3.2 with less decentralized PHA-enrichment system requires the least specific cost with regard to PHA produced amount. Therefore, it is the most recommended. As alternative options, variant 2.2 and variant 3.1 with four decentralized PHA-enrichment system can also be considered.

Table 6-13: Cost for all variants

		Cost					
		Primary sludge transport		PHA rich biomass transport			
		Var. 1.1	Var.1.2	Var. 2.1	Var. 2.2	Var.3.1	Var.3.2
CAPEX (€/y)		3,816,138	5,609,072	7,740,890	7,174,002	7,240,522	7,025,566
OPEX (€/y)	OPEX excluding cost for transport, labor, maintainance, insurance exclusive	19,031,297	23,104,947	20,167,805	20,219,929	20,219,929	21,360,111
	Transport cost	3,131,777	2,077,410	109,258	171,245	66,364	185,435
	Labor and maintainance cost	1,342,199	2,059,150	6,360,856	4,210,003	4,835,251	3,701,468
	insurance cost	19,081	28,045	38,704	35,870	36,203	35,128
Sum (€/y)		27,340,491	32,878,624	34,417,514	31,811,048	32,398,268	32,307,708
PHA production (tons/y)		5,610	6,440	5,107	5,120	5,120	5,409
Specific cost (€/ton PHA)		4,874	5,106	6,739	6,213	6,328	5,973

6.3 Germany / Saarland

Due to the low population density in the Saarland region and the associated high transport costs, the implementation of a central PHA extraction plant in this region is not economically viable and is therefore not considered in detail. Within the framework of the GIS analysis, potentially suitable wastewater treatment plants could be identified for Germany. The costs incurred are even more favourable compared to the Glasgow region in Scotland, as the transport kilometres and the wastewater treatment plants considered are lower.

6.4 Ireland

The results of the GIS tool show that the Dublin region has the shortest distances between the central PHA extraction plant and the decentralized plants. Therefore 2 potentially suitable variants for PHA-production, one with primary sludge transport and one with PHA rich biomass transport, were investigated for the Dublin region.

6.4.1 Primary sludge transport

Central

In this variant, the central plant with PHA-enrichment system, PHA-extraction system and compounding system is set in Ringsend WWTP with a physical capacity of 1,640,000 PE. Three other WWTPs within 25km from Ringsend WWTP are selected to provide primary sludge. The physical loading, primary sludge amount of central plant and primary sludge suppliers and distance from primary sludge suppliers to central plant are summarized in




Figure 6-13 and Table 6-14. The total truck kilometres for dried and dewatered PHA-rich biomass transport results for variant 3.2 to 75,374 km/y According to the mass balance, the PHA production amount of this variant is estimated as 5,140 t/y.




Figure 6-13: GIS-result: Scenario with primary sludge transport and one central plant




Figure 6-14: Scenario with primary sludge transport and one central plant

Table 6-14: involved WWTPs in Variant 1.1

	WWTP	Loading entering (PE)	PS (tons/y)	PS DM (tons/y)	PHA-rich biomass (tons/y)	frequency (1/y)	truck kilometers (t*km/a)	Distance to central plant (km)
Central plant								
0	Ringsend WWTP	1,640,000	698,367	20,951				-
Dewatered PHA-rich biomass supplier								
1	Swords WWTP	60,000	25,550	767	909	36	656	18.0
2	Leixlip WWTP	150,000	63,875	1,916	2,272	91	1,919	21.1
3	Shanganagh WWTP	186,000	79,205	2,376	2,818	113	1,893	16.8
	Sum PHA-rich biomass supplier	396,000	168,630	5,059	5,999		4,469	

6.4.2 PHA rich biomass transport

In this variant there is one central plant and three decentralized PHA enrichment plants. The PHA-rich biomass is dewatered and transported to the central plant. Due to the relatively low capacity of the decentral PHA enrichment plants a dryer for the PHA enriched biomass is not considered at the decentral plants. In Table 6-15 the entering loading, primary sludge amount of selected WWTPs, the distance from dewatered PHA-rich biomass suppliers to central plant is separately summarized. The produced primary sludge amount in each plant is estimated based on the entering loading and two assumptions that the specific primary sludge production is 35 g DM/PE/d and the DM-content in primary sludge is 3%. The total truck kilometres for dewatered PHA-rich biomass transport results to 4,469 km/y According to the mass balance, a PHA production of 5,140 t/a can be expected.




Figure 6-15: GIS-result: variant 1.2 with one central plant and 3 decentral plants providing dewatered PHA-rich biomass

PHA-enrichment system		
WWTP	Entering loading (PE)	Distance (km)
Swords WWTP	60,000	18.0
Leixlip WWTP	150,000	21.1
Shanganagh WWTP	186,000	16.8

Central plant	
WWTP	Entering loading (PE)
Ringsend WWTP	1,640,000
PHA-production (t/a)	5,140
Truck*km/a	101,178




Figure 6-16: variant 1.2 with one central plant and 3 decentral plants providing dewatered PHA-rich biomass

Table 6-15: involved WWTPs in variant 1.2

	WWTP	Loading entering (PE)	PS (tons/y)	PS DM (tons/y)	PHA-rich biomass (tons/y)	frequency (1/y)	truck kilometers (f*km/a)	Distance to central plant (km)
Central plant								
0	Ringsend WWTP	1,640,000	698,367	20,951				-
Dewatered PHA-rich biomass supplier								
1	Swords WWTP	60,000	25,550	767	909	36	656	18.0
2	Leixlip WWTP	150,000	63,875	1,916	2,272	91	1,919	21.1
3	Shanganagh WWTP	186,000	79,205	2,376	2,818	113	1,893	16.8
	Sum PHA-rich biomass supplier	396,000	168,630	5,059	5,999		4,469	

6.4.3 Estimated cost

The estimated cost for variant 1.1 with primary sludge transport is 5,082 €/tonon PHA, which are lower than the cost of the second variant with 5.688 €/tonon PHA. The cost breakdown for variant 1.1 and 1.2 are shown in Table 6-16 and Table 6-17.

Table 6-16: Cost for variant 1.1

	WWTP	CAPEX (€/y)	OPEX (€/y)				Sum (€/y)
			OPEX excluding cost for transport, labor, maintainance, insurance	Transport cost	Labor and maintainance cost	Insurance cost	
Central plant							
0	Ringsend WWTP	4,461,915	19,545,865	0	1,342,199	22,310	25,372,289
Dewatered PHA-rich biomass supplier							
1	Swords WWTP	0	0	110,669	0	0	110,669
2	Leixlip WWTP	0	0	323,736	0	0	323,736
3	Shanganagh WWTP	0	0	319,334	0	0	319,334
Sum (€/y)		4,461,915	19,545,865	753,739	1,342,199	22,310	26,126,028
Specific cost (€/ton PHA)		868	3,802	147	261	4	5,082

Table 6-17: Cost for variant 1.2

	WWTP	CAPEX (€/y)	OPEX (€/y)				Sum (€/y)
			OPEX excluding cost for transport, labor, maintainance, insurance	Transport cost	Labor and maintainance cost	Insurance cost	
Central plant							
0	Ringsend WWTP	4,139,997	18,462,077	0	1,342,199	20,700	23,964,973
Dewatered PHA-rich biomass supplier							
1	Swords WWTP	356,192	278,319	6,562	716,951	1,781	1,359,805
2	Leixlip WWTP	674,253	695,797	19,194	716,951	3,371	2,109,566
3	Shanganagh WWTP	783,928	294,229	8,730	716,951	1,851	1,805,690
Sum (€/y)		5,954,370	19,730,422	34,486	3,493,052	27,703	29,240,034
Specific cost (€/ton PHA)		1.158	3.838	7	680	5	5.688

6.4.4 Recommendation

In Table 6-18 the estimated cost for all variants is summarized. Based on estimated results, the variant 1.1 with primary sludge transport shows with 5,082 €/ton PHA the least cost requirement, because only one PHA-enrichment plant at the central plant is necessary. However, this is associated with high efforts for the transport of the primary sludge of the decentral plants. In contrast, variant 1.2 with three decentralized PHA plants has low transport costs, but higher capital costs for the installation of the PHA plants on the decentralized WWTPs. The specific costs amount to 5,688 €/ton PHA.

Table 6-18: Cost for all variants

Cost		Primary sludge transport	PHA rich biomass transport
		Var. 1.1	Var.1.2
CAPEX (€/y)		4,461,915	5,954,370
OPEX (€/y)	OPEX excluding cost for transport, labor, maintainance, insurance exclusive	19,545,865	19,730,422
	Transport cost	753,739	34,486
	Labor and maintainance cost	1,342,199	3,493,052
	insurance cost	22,310	27,703
Sum (€/y)		26,126,028	29,240,034
PHA production (t/y)		5,140	5,140
Specific cost (€/ton PHA)		5,082	5,688

7 Conclusions

Within the framework of WOW! Project, the market potential and technical feasibility for production of bioplastic from sewage with primary sludge as feedstock has been proved. However, an estimate of economic viability has shown that this requires a WWTP size of approximately 2 million PE (Nazeer Khan, 2020). Since in most regions in NWE, WWTP connection sizes are typically below 2 million PE. The following concepts for an economic production of PHA considering several WWTP sites were developed:

- Transport of primary sludge to a central plant for the enrichment, extraction and compounding of PHA.
- Decentralized plants for the enrichment of PHA and transport of PHA-rich biomass to a and a central plant for PHA extraction and compounding

The advantages and disadvantages with respect to the operation of the treatment plants and the required technical equipment were discussed. Due to the poor data basis for the individual sites such as sludge production, digester size, capacity of the biological stage and sludge digestion, it was not possible to perform a detailed analysis on the effects on each WWTP. However, these aspects have to be considered monetarily when planning a PHA production plant.

Using the GIS tool, optimal sites for PHA production could be identified for three different catchment areas in NWE. For the Scotland region, 3 sites for a centralized treatment plant were analyzed, of which Glasgow was most viable. The Glasgow region had the best boundary conditions due to the high population density, a high number of wastewater treatment plants with a capacity greater than 50,000 PE and a single driving distance to the central site of less than 70 km.

For the Saarland region, a very rural area, it was shown that only by taking into account wastewater treatment plants outside the catchment area, a sufficient amount of primary sludge can be acquired for a central PHA extraction plant. Also the chosen location for the PHA production facility was chosen outside the area of Saarland. Also, this involves long transport distances of up to 125 km single driving distance. Therefore, a site search for the whole of Germany was carried out within the framework of the GIS study. It was found that there are 8 target locations for the whole of Germany next to the single facilities that could already be self-supporting having over 2 million PE. The important is here the boundary condition of taking into account only WWTPs over 300,000 PE, so only dries sludge is being transported.

For the region of Ireland, only one central WWTP location could be identified. However, the Dublin region has an ideal location for a PHA production plant with the Ringsend WWTP with 1.6 million PE. With the surrounding wastewater treatment plants, sufficient primary sludge can be provided.

An economic feasibility study was carried out for the Glasgow and Dublin regions. For the rural region of Saarland, no detailed economic feasibility analysis was carried out. Due to the long transport distances between the decentral and central plant, the specific costs were very high.

Five different variants were investigated for the Glasgow region. The lowest specific costs of 4,870 €/ton PHA result from a central PHA enrichment and extraction plant. However, this involves high cost for the transport of the primary sludge from the decentralized plants to the central site. This requires storage of the primary sludge at both sites. Furthermore, sufficient capacity in the biological stage and sludge digestion at the central site is required to treat the reject water of the additional primary sludge from the decentralized sites. Therefore, this alternative is not recommended for implementation.

Slightly higher specific costs of 6,200 €/ton PHA result from the implementation of decentralized plants for PHA enrichment and transport of the dewatered PHA-enriched biomass. The advantage of this variant is that the reject water from the PHA enrichment can be treated directly at the site. In addition to the transport of the dewatered PHA enriched biomass, the transport of dried sludge was also considered for long distances between the decentral plant and the central plant. Hereby, the transport costs can be reduced significantly. Due to the additional costs for the dryer, specific costs of 6,000 €/ton PHA result in the investigated case.

Two variants were investigated for the Dublin region. Due to the high connection size of the central plant of 1.6 million PE, only three additional wastewater treatment plants have to be considered to reach the required connection size of 2 million PE. The transport of primary sludge from the decentralized plants to the central plant results in specific costs of 5,100 €/ton PHA. With the consideration of PHA enrichment plants on the decentralized plants, specific costs of 5,700 €/ton PHA result.

Due to the decrease of the specific investment costs in dependence of the plant size, the most cost-effective solutions result especially for densely populated regions like Glasgow and Dublin. The Saarland region shows unfavorable boundary conditions for a PHA production plant due to the high number of wastewater treatment plants with a relatively small connection size. Considering industrial wastewater streams from the food industry with higher PHA yield rates, the specific costs can be reduced. This can result in economic solutions also for regions with WWTP with a size.

8 Literature

Nazeer Khan; M; Uhrig, T.; Steinmetz, H.; de Best, J.; Raingue, A.: WOW (2020): Techno-economic assessment of producing bioplastics from sewage
https://www.nweurope.eu/media/16741/1wpt1_deliverable_3_1_pha_tea_final.pdf, Zugriff am 13.12.2022

Coelen Molina, Niels: Graduation Thesis Report - Assessment of potential cooperation for select European sewage treatment plants for the production of polyhydroxyalkanoates, July 2022

10 Appendix

Table 10-1: Summary of the results for the variants 1.1 and 1.2 for Scotland

Description	unit	Variant 1.1					Variant 1.2		
		Central	PS transport	Partial decentral	PS transport	Sum	Central	PS transport	Sum
WWTP	-	SHIELDHALL S.T.W.	-	EDINBURGH, SEAFIELD	-		-	-	
PE	E	563,713	1,023,515	764,659	198,692	2,550,579	581,220	1,640,574	2,221,794
Primary sludge	t/a	240,048	0	325,617	0	565,665	247,503	0	247,503
Primary sludge transport	t/a	0	261,508	0	50,766	312,274	0	419,167	419,167
PS Transport (t*km/a)	t*km/a	0	105,539	0	51,999	157,538	0	313,178	313,178
recieved PS (t/a)	t/a	261,508	0	50,766	0	312,274	419,167	0	419,167
recieved PHA Biomass (wet) (t/a)	t/a	14,593	0	0	0	14,593	0	0	0
recieved PHA Biomass (dry) (t/a)	t/a	0	0	0	0	0	0	0	0
PHA-r, BM (wet) transport distance (km)	km	0	0	86	0	86	0	0	0
PHA-r, BM (dry) transport distance (km)	km	0	0	0	0	0	0	0	0
PHA enriched sludge (wet) used in this plant	t/a	0	0	0	0	0	30,836	0	30,836
PHA Biomass (wet) transport (t/a)	t/a	0	0	14,593	0	14,593	0	0	0
PHA Biomass (wet) Transport (t*km/a)	t*km/a	0	0	50,203	0	50,203	0	0	0
PHA Biomass (dry) transport (t/a)	t/a	0	0	0	0	0	0	0	0
PHA Biomass (dry) Transport (t*km/a)	t*km/a	0	0	0	0	0	0	0	0
PHA Production	t/a	6,440	0	0	0	6,440	5,610	0	5,610
required secondary sludge amount (thickened)	t/a	62,298	0	50,766	0	113,064	80,831	0	80,831
secondary sludge produced by WWTP	t/a	144,029	261,508	195,370	50,766	651,673	148,502	419,167	567,668
OPEX									
DMC	Dimethyl carbonate (DMC)	€/a	1,223,527	0	0	1,223,527	1,065,807	0	1,065,807
Electricity	€/a	7,305,377	0	3,689,789	0	10,995,166	8,595,902	0	8,595,902
Natural gas (heat)	€/a	1,668,930	0	299,450	0	1,968,380	1,636,598	0	1,636,598
Steam	€/a	363,507	0	0	0	363,507	316,649	0	316,649
Cooling water	€/a	48,735	0	0	0	48,735	42,452	0	42,452
Process water	€/a	124,596	0	101,531	0	226,127	161,663	0	161,663
Raw materials (RM)	€/a	8,279,505	0	0	0	8,279,505	7,212,227	0	7,212,227
PHA biomass transport cost	€/a	0	0	502,034	0	502,034	0	0	0
primary sludge transport	€/a	0	1,055,386	0	519,990	1,575,376	0	3,131,777	3,131,777
Labor	€/a	803,712	0	429,312	0	1,233,024	803,712	0	803,712
maintenance cost	€/a	538,487	0	287,639	0	826,126	538,487	0	538,487
insurance	€/a	16,406	0	11,640	0	28,045	19,081	0	19,081
Sum	€/a	20,372,781	1,055,386	5,321,395	519,990	27,269,553	20,392,577	3,131,777	23,524,354
Investment									
Civil Works	€	15,980,057	0	11,337,935	0	27,317,992	18,585,823	0	18,585,823
Mechanical Equipment	€	25,111,518	0	17,816,755	0	42,928,273	29,206,293	0	29,206,293
Electrical Equipment	€	4,565,731	0	3,239,410	0	7,805,141	5,310,235	0	5,310,235
Sum		45,657,306	0	32,394,100	0	78,051,406	53,102,350	0	53,102,350
CAPEX									
Civil Works	€/a	818,506	0	580,734	0	1,399,240	951,974	0	951,974
Mechanical Equipment	€/a	1,954,316	0	1,386,597	0	3,340,913	2,272,994	0	2,272,994
Electrical Equipment	€/a	508,287	0	360,632	0	868,919	591,170	0	591,170
Sum	€/a	3,281,108	0	2,327,964	0	5,609,072	3,816,138	0	3,816,138
Yearly cost									
CAPEX	€/a	3,281,108	0	2,327,964	0	5,609,072	3,816,138	0	3,816,138
OPEX	€/a	20,372,781	1,055,386	5,321,395	519,990	27,269,553	20,392,577	3,131,777	23,524,354
Sum	€/a	23,653,889	1,055,386	7,649,359	519,990	32,878,624	24,208,714	3,131,777	27,340,491

Table 10-2: Summary of the results for the variants 2.1 and 2.2 for Scotland

			Variant 2.1									
	Description	unit	Central	Dewatered, PHA-rich Biomass								
	WWTP	-	SHELDHALL S.T.W.	DALMUIR S.T.W.	DALDOWIE S.T.W.	DALMARNO CK S.T.W.	LAIGH-PARK S.T.W.	ERSKINE S.T.W.	HAMILTON'S T.W.	PHILIPSHILL S.T.W.	Sum	
PE		E	563,713	581,220	317,927	232,840	126,440	83,015	63,430	54,258	2,022,843	
Primary sludge		t/a	240,048	247,503	135,384	99,151	53,842	35,351	27,011	23,105	861,394	
Primary sludge transport		t/a	0	0	0	0	0	0	0	0	0	
PS Transport (t*km/a)		t*km/a	0	0	0	0	0	0	0	0	0	
recieved PS (t/a)		t/a	0	0	0	0	0	0	0	0	0	
recieved PHA Biomass (wet) (t/a)		t/a	22,104	0	0	0	0	0	0	0	22,104	
recieved PHA Biomass (dry) (t/a)		t/a	0	0	0	0	0	0	0	0	0	
PHA-r, BM (wet) transport distance (km)		km	0	11	17	10	7	7	23	16	91	
PHA-r, BM (dry) transport distance (km)		km	0	0	0	0	0	0	0	0	0	
PHA enriched sludge (wet) used in this plant		t/a	0	0	0	0	0	0	0	0	0	
PHA Biomass (wet) transport (t/a)		t/a	0	8,805	4,816	3,527	1,915	1,258	961	822	22,104	
PHA Biomass (wet) Transport (t*km/a)		t*km/a	0	3,985	3,270	1,392	537	343	873	525	10,926	
PHA Biomass (dry) transport (t/a)		t/a	0	0	0	0	0	0	0	0	0	
PHA Biomass (dry) Transport (t*km/a)		t*km/a	0	0	0	0	0	0	0	0	0	
PHA Production		t/a	5,107	0	0	0	0	0	0	0	5,107	
required secondary sludge amount (thickened)		t/a	0	0	0	0	0	0	0	0	0	
secondary sludge produced by WWTP		t/a	33,271	34,304	18,764	13,742	7,463	4,900	3,744	3,202	119,389	
OPEX												
DMC	Dimethyl carbonate (DMC)	€/a	970,369	0	0	0	0	0	0	0	970,369	
Electricity		€/a	4,271,032	2,430,553	1,329,511	973,693	528,748	347,153	265,252	226,897	10,372,840	
Natural gas (heat)		€/a	1,198,123	196,913	107,711	78,885	42,837	28,125	21,490	18,382	1,692,466	
Steam		€/a	288,295	0	0	0	0	0	0	0	288,295	
Cooling water		€/a	38,651	0	0	0	0	0	0	0	38,651	
Process water		€/a	66,541	68,608	37,528	27,485	14,925	9,799	7,487	6,405	238,778	
Raw materials (RM)		€/a	6,566,406	0	0	0	0	0	0	0	6,566,406	
PHA biomass transport cost		€/a	0	39,854	32,704	13,923	5,367	3,428	8,730	5,252	109,258	
primary sludge transport		€/a	0	0	0	0	0	0	0	0	0	
Labor		€/a	803,712	429,312	429,312	429,312	429,312	429,312	429,312	429,312	3,808,896	
maintenance cost		€/a	538,487	287,639	287,639	287,639	287,639	287,639	287,639	287,639	2,551,960	
insurance		€/a	10,908	8,757	5,715	4,589	2,992	2,231	1,851	1,661	38,704	
Sum		€/a	14,752,524	3,461,637	2,230,120	1,815,526	1,311,820	1,107,688	1,021,762	975,547	26,676,624	
Investment												
Civil Works		€	10,625,201	8,530,217	5,566,601	4,470,272	2,914,035	2,173,361	1,802,930	1,618,016	37,700,635	
Mechanical Equipment		€	16,696,744	13,404,627	8,747,516	7,024,714	4,579,198	3,415,282	2,833,176	2,542,597	59,243,885	
Electrical Equipment		€	3,035,772	2,437,205	1,590,457	1,277,221	832,581	620,960	515,123	462,290	10,771,610	
Sum		€	30,357,717	24,372,050	15,904,574	12,772,206	8,325,815	6,209,604	5,151,230	4,622,903	107,716,099	
CAPEX												
Civil Works		€/a	544,227	436,921	285,124	228,969	149,258	111,321	92,347	82,875	1,931,043	
Mechanical Equipment		€/a	1,299,432	1,043,221	680,780	546,702	356,378	265,796	220,493	197,879	4,610,681	
Electrical Equipment		€/a	337,962	271,326	177,060	142,189	92,688	69,129	57,347	51,465	1,199,166	
Sum		€/a	2,181,621	1,751,468	1,142,963	917,859	598,325	446,246	370,187	332,219	7,740,890	
Yearly cost												
CAPEX		€/a	2,181,621	1,751,468	1,142,963	917,859	598,325	446,246	370,187	332,219	7,740,890	
OPEX		€/a	14,752,524	3,461,637	2,230,120	1,815,526	1,311,820	1,107,688	1,021,762	975,547	26,676,624	
Sum		€/a	16,934,146	5,213,105	3,373,084	2,733,385	1,910,145	1,553,934	1,391,949	1,307,767	34,417,514	

			Variant 2.2					
	Description	unit	Central	Dewatered, PHA-rich Biomass				
	WWTP	-	SHIELDHALL S.T.W.	DALMUIR PFI	MEADOWHIE AD W.W.T.	DALDOWIE S.T.W.	DALMARNO CK S.T.W.	Sum
PE		E	563,713	581,220	332,371	317,927	232,840	2,028,071
Primary sludge		t/a	240,048	247,503	141,535	135,384	99,151	863,620
Primary sludge transport		t/a	0	0	0	0	0	0
PS Transport (t*km/a)		t*km/a	0	0	0	0	0	0
recieved PS (t/a)		t/a	0	0	0	0	0	0
recieved PHA Biomass (wet) (t/a)		t/a	22,183	0	0	0	0	22,183
recieved PHA Biomass (dry) (t/a)		t/a	0	0	0	0	0	0
PHA-r, BM (wet) transport distance (km)		km	0	11	42	17	10	80
PHA-r, BM (dry) transport distance (km)		km	0	0	0	0	0	0
PHA enriched sludge (wet) used in this plant		t/a	0	0	0	0	0	0
PHA Biomass (wet) transport (t/a)		t/a	0	8,805	5,035	4,816	3,527	22,183
PHA Biomass (wet) Transport (t*km/a)		t*km/a	0	3,985	8,476	3,270	1,392	17,125
PHA Biomass (dry) transport (t/a)		t/a	0	0	0	0	0	0
PHA Biomass (dry) Transport (t*km/a)		t*km/a	0	0	0	0	0	0
PHA Production		t/a	5,120	0	0	0	0	5,120
required secondary sludge amount (thickened)		t/a	0	0	0	0	0	0
secondary sludge produced by WWTP		t/a	33,271	34,304	19,617	18,764	13,742	119,696
OPEX								
DMC	Dimethyl carbonate (DMC)	€/a	972,877	0	0	0	0	972,877
Electricity		€/a	4,275,978	2,430,553	1,389,913	1,329,511	973,693	10,399,649
Natural gas (heat)		€/a	1,200,726	196,913	112,605	107,711	78,885	1,696,840
Steam		€/a	289,040	0	0	0	0	289,040
Cooling water		€/a	38,751	0	0	0	0	38,751
Process water		€/a	66,541	68,608	39,233	37,528	27,485	239,396
Raw materials (RM)		€/a	6,583,377	0	0	0	0	6,583,377
PHA biomass transport cost		€/a	0	39,854	84,764	32,704	13,923	171,245
primary sludge transport		€/a	0	0	0	0	0	0
Labor		€/a	803,712	429,312	429,312	429,312	429,312	2,520,960
maintenance cost		€/a	538,487	287,639	287,639	287,639	287,639	1,689,043
insurance		€/a	10,912	8,757	5,897	5,715	4,589	35,870
Sum		€/a	14,780,401	3,461,637	2,349,363	2,230,120	1,815,526	24,637,047
Investment								
Civil Works		€	10,628,767	8,530,217	5,743,847	5,566,601	4,470,272	34,939,705
Mechanical Equipment		€	16,702,348	13,404,627	9,026,046	8,747,516	7,024,714	54,905,251
Electrical Equipment		€	3,036,791	2,437,205	1,641,099	1,590,457	1,277,221	9,982,773
Sum		€	30,367,906	24,372,050	16,410,992	15,904,574	12,772,206	99,827,729
CAPEX								
Civil Works		€/a	544,410	436,921	294,202	285,124	228,969	1,789,627
Mechanical Equipment		€/a	1,299,868	1,043,221	702,456	680,780	546,702	4,273,027
Electrical Equipment		€/a	338,075	271,326	182,698	177,060	142,189	1,111,347
Sum		€/a	2,182,354	1,751,468	1,179,357	1,142,963	917,859	7,174,002
Yearly cost								
CAPEX		€/a	2,182,354	1,751,468	1,179,357	1,142,963	917,859	7,174,002
OPEX		€/a	14,780,401	3,461,637	2,349,363	2,230,120	1,815,526	24,637,047
Sum		€/a	16,962,754	5,213,105	3,528,720	3,373,084	2,733,385	31,811,049

Table 10-3: Summary of the results for the variants 3.1 and 3.2 for Scotland

		Variant 3.1						Variant 3.2					
	Description	unit	Central	Dried PHA-rich Biomass			Dewatered, PHA-rich Biomass		Central	Dewatered, PHA-rich Biomass	PHA-rich Biomass	Dried PHA-rich Biomass	
	WWTP	-	SHIELDHALL S.T.W.	DALMUIR PFI	MEADOWHIE AD W.W.T.	DALDOWIE S.T.W.	DALMARNOCK S.T.W.	Sum	SHIELDHALL S.T.W.	DALMUIR S.T.W.	DALMARNOCK S.T.W.	EDINBURGH, SEAFIELD	Sum
PE		E	563,713	581,220	332,371	317,927	232,840	2,028,071	563,713	581,220	232,840	764,659	2,142,432
Primary sludge		t/a	240,048	247,503	141,535	135,384	99,151	863,620	240,048	247,503	99,151	325,617	912,319
Primary sludge transport		t/a	0	0	0	0	0	0	0	0	0	0	0
PS Transport (t*km/a)		t*km/a	0	0	0	0	0	0	0	0	0	0	0
recieved PS (t/a)		t/a	0	0	0	0	0	0	0	0	0	0	0
recieved PHA Biomass (wet) (t/a)		t/a	3,527	0	0	0	0	3,527	12,332	0	0	0	12,332
recieved PHA Biomass (dry) (t/a)		t/a	6,219	0	0	0	0	6,219	3,861	0	0	0	3,861
PHA-r. BM (wet) transport distance (km)		km	0	0	0	0	10	10	10	11	10	0	21
PHA-r. BM (dry) transport distance (km)		km	0	11	42	17	0	70	0	0	0	85	85
PHA enriched sludge (wet) used in this plant		t/a	0	0	0	0	0	0	0	0	0	0	0
PHA Biomass (wet) transport (t/a)		t/a	0	0	0	0	3,527	3,527	0	8,805	3,527	0	12,332
PHA Biomass (dry) transport (t/a)		t/a	0	0	0	0	1,392	1,392	0	3,985	1,392	0	5,378
PHA Biomass (dry) transport (t*km/a)		t*km/a	0	2,935	1,678	1,605	0	6,219	0	0	0	3,861	3,861
PHA Biomass (dry) Transport (t*km/a)		t*km/a	0	1,328	2,825	1,090	0	5,244	0	0	0	13,166	13,166
PHA Production		t/a	5,120	0	0	0	0	5,120	5,409	0	0	0	5,409
required secondary sludge amount (thickened)		t/a	0	0	0	0	0	0	0	0	0	0	0
secondary sludge produced by WWTP		t/a	33,271	34,304	19,617	18,764	13,742	119,698	33,271	34,304	13,742	45,131	126,447
OPEX													
DMC	Dimethyl carbonate (DMC)	€/a	972,877	0	0	0	0	972,877	1,027,736	0	0	0	1,027,736
Energy	Electricity	€/a	4,090,913	2,517,895	1,439,860	1,377,287	973,693	10,399,649	4,269,260	2,430,553	973,693	3,312,569	10,986,075
	Natural gas (heat)	€/a	587,573	486,293	278,087	266,002	78,885	1,696,840	876,953	196,913	78,885	639,772	1,792,523
resource consumption	Steam	€/a	289,040	0	0	0	0	289,040	305,338	0	0	0	305,338
	Cooling water	€/a	38,751	0	0	0	0	38,751	40,936	0	0	0	40,936
	Process water	€/a	66,541	68,608	39,233	37,528	27,485	239,396	66,541	68,608	27,485	90,261	252,895
input	Raw materials (RM)	€/a	6,583,377	0	0	0	0	6,583,377	6,954,607	0	0	0	6,954,607
transport	PHA biomass transport cost	€/a	0	13,285	28,255	10,901	13,923	66,364	0	39,854	13,923	131,658	185,435
	primary sludge transport	€/a	0	0	0	0	0	0	0	0	0	0	0
	Labor	€/a	803,712	554,112	554,112	554,112	429,312	2,895,360	803,712	429,312	429,312	554,112	2,216,448
Others	maintenance cost	€/a	538,487	371,255	371,255	371,255	287,639	1,939,891	538,487	287,639	287,639	371,255	1,485,020
	insurance	€/a	10,711	8,979	6,055	5,869	4,589	36,203	10,878	8,757	4,589	10,903	35,128
Sum		€/a	13,981,981	4,020,427	2,716,857	2,622,955	1,815,526	25,157,746	14,894,450	3,461,637	1,815,526	5,110,530	25,282,142
Investment													
Civil Works		€	10,432,934	8,745,780	5,897,997	5,716,696	4,470,272	35,263,680	10,596,165	8,530,217	4,470,272	10,620,121	34,216,776
Mechanical Equipment		€	16,394,611	13,743,369	9,268,281	8,983,379	7,024,714	55,414,354	16,651,117	13,404,627	7,024,714	16,688,761	53,769,219
Electrical Equipment		€	2,980,838	2,498,794	1,685,142	1,633,342	1,277,221	10,075,337	3,027,476	2,437,205	1,277,221	3,034,320	9,776,222
Sum		€	29,808,384	24,987,943	16,851,420	16,333,417	12,772,206	100,753,370	30,274,757	24,372,050	12,772,206	30,343,203	97,762,216
CAPEX													
Civil Works		€/a	534,379	447,963	302,098	292,812	228,969	1,806,221	542,740	436,921	228,969	543,967	1,752,598
Mechanical Equipment		€/a	1,275,918	1,069,584	721,308	699,136	546,702	4,312,648	1,295,881	1,043,221	546,702	1,298,811	4,184,615
Electrical Equipment		€/a	331,846	278,182	187,601	181,834	142,189	1,121,652	337,038	271,326	142,189	337,800	1,089,353
Sum		€/a	2,142,144	1,795,729	1,211,007	1,173,782	917,859	7,240,522	2,175,660	1,751,468	917,859	2,180,578	7,025,566
Yearly cost													
CAPEX		€/a	2,142,144	1,795,729	1,211,007	1,173,782	917,859	7,240,522	2,175,660	1,751,468	917,859	2,180,578	7,025,566
OPEX		€/a	13,981,981	4,020,427	2,716,857	2,622,955	1,815,526	25,157,746	14,894,450	3,461,637	1,815,526	5,110,530	25,282,142
Sum		€/a	16,124,126	5,816,156	3,927,865	3,796,737	2,733,385	32,398,268	17,070,109	5,213,105	2,733,385	7,291,108	32,307,704

Table 10-4: Assumptions for the cost calculation

Depreciation			
1	Civil Works	25	a
2	Mechanical Equipment	15	a
3	Electrical Equipment	10	a
4	Interest rate	2	%
Operation cost			
1	Insurance	0.50%	%Investment
2	Electricity	93	€/MWh
3	Natural gas	34	€/MWh
4	Steam	24.6	€/t
5	Cooling water	0.5	€/m3
6	Process water	1	€/m3
7	Dimethyl carbonate	1	€/kg
8	Raw materials	3	€/kg
9	staff costs	31.2	€/h
10	maintenance cost	67%	%labor
11	transport cost (for PHA& Biomass)	10.00	€/truck/km

Contribution to this report

DE: Wupperverbandsgesellschaft für integrale Wasserwirtschaft mbH, WiW

NL: Avans University of Applied Sciences, Avans